

CERTIFICATE OF CONFORMITY

Product: **Structural Fasteners in the OMF-CON-KT**

Structural Fastener Components:

This document certifies that the following components have been used in the structural fastener assembly described below:

- ASTM A325 7/8 x 3 heavy hex bolt
- ASTM A563 grade C, C3, D, DH, or DH3; or A194 grade 2H 7/8" heavy hex nut
- ASTM F436 7/8" hardened washer
- ASTM F959 type 325 7/8" direct tension indicating washer

Structural Fastener Assembly:

This document certifies that the assembly lot listed below has been randomly sampled and the samples tested to the pre-installation verification requirements for pretensioned joints, as applicable, in accordance with Section 7 of *Specification for Structural Joints Using ASTM A325 or A490 Bolts, June 30, 2004* as required by *AISC Steel Construction Manual 13th Edition*. The sample assemblies were found to be in conformance with the pre-installation verification requirements of Section 8.2.4 and the minimum bolt pretension in Table 8.1.

Assembly Lot #:	52-330754000
Lot Date:	09/08/2011
Test Date:	09/09/2011

Sincerely,

A handwritten signature in black ink that reads "Leland Manhart".

Leland Manhart
Receiving Lab Manager
Simpson Strong-Tie Company, Inc.

Lab Certificates and Accreditations:

- Registered ISO 9001:2000, by ANAB and UKAS
- Testing Laboratory TL-326 Certificate of Accreditation in compliance with ANS/ISO/IEC Standard 17025:2005 by International Accreditation Services, Inc. (IAS).

