

## CERTIFICATE OF CONFORMITY

Product: Structural bolt assembly in the OMF-CON-KT


Structural Bolt Assembly Components:

- ASTM A325 7/8 x 3 heavy hex bolt
- ASTM A563 grade C, C3, D, DH, or DH3; or A194 grade 2H 7/8" heavy hex nut
- ASTM F436 7/8" hardened washer
- ASTM F959 type 325 7/8" direct tension indicating washer

This document certifies that the assembly lot listed below has been randomly sampled and the samples tested to the pre-installation verification requirements for slip-critical joints, as applicable, to Part 16 *Specification for Structural Joints Using ASTM A325 or A490 Bolts, June 30, 2004*, Section 7 of the *AISC Steel Construction Manual 13<sup>th</sup> Edition*, pages 16.2-43 through 16.2.45. The sample assemblies were found to be in conformance with *AISC Steel Construction Manual*, Page 16.2-51, Section 8.2.4 and Table 8.1, page 16.2-47.

<b>Assembly Lot #:</b>	SBA001
<b>Lot Date:</b>	12/12/2008
<b>Work Order #:</b>	52-322906
<b>Test Date:</b>	01/20/2009

Sincerely,

A handwritten signature in black ink that reads "Leland Manhart".

Leland Manhart  
Receiving Lab Manager  
Simpson Strong-Tie Company, Inc.

Lab Certificates and Accreditations:

- Registered ISO 9001:2000, by ANAB and UKAS
- Testing Laboratory TL-326 Certificate of Accreditation in compliance with ANS/ISO/IEC Standard 17025:2005 by International Accreditation Services, Inc. (IAS).